



- NOTE: 1. ALL THRUST BLOCKS TO BE POURED AGAINST UNDISTURBED SOIL AND TO HAVE A MINIMUM THICKNESS BETWEEN FOOTING AND SOIL OF 12".
2. ALL DIMENSIONS SHOWN ARE MINIMUM.
3. CONCRETE TO BE FIVE-SACK MIX.
4. SUPPORT AND PROTECT ALL PIPE.

STANDARD THRUST BLOCK DETAILS

REVISIONS
12-8-05
03-23-10

CITY OF KERMAN

STD
NO.
W-9